

**City of Springfield
Development and Public Works Department**



Authorized by:

Title:

Date:

Jeff Raschall
Managing Civil Engineer
6/25/15

June 25, 2015

**Addendum Number 2 to the Contract Documents for the
Request for Competitive Price Quote for P21052; Springfield Mill Race
Stormwater Facility, Booth Kelly Trailhead and Mill Race Path**

The City of Springfield is amending the above mentioned Request for Competitive Price Quote issued on June 10, 2015. This Addendum is hereby made a part of the original contract documents to the same extent as though it were originally included therein.

1.) Question: I am unable to locate the spec for installation and material type for the 48 inch HDPE pipe and its corresponding specs.

Response: The 48-inch HDPE pipe shall be corrugated (shown on C-14/A3) Type S (per AASHTO M294) with a minimum SDR of 26. This information can be found in 00445.11 and 02415.10.

2.) Delete Section 00745.96 Asphalt Cement Price Adjustments in its entirety.

In the event that it is necessary to further amend, revise or supplement any part this Request for Competitive Price Quote additional addenda will be posted on the City's website at <http://www.springfield-or.gov/dpw/P21052MillRaceTrailHead.htm>.

The City shall make a reasonable effort to notify all individuals, firms, and corporations that were included in the initial solicitation and those individuals that attended a Pre-Quote Informational meeting and provided a valid e-mail address on the sign-in sheet when addenda are issued. Failure of the Contractor to receive or obtain such addenda shall not excuse them from compliance, if they are awarded the Contract.

All Addenda issued are considered to be part of the specifications of the Request for Competitive Price Quote and, as such, are incorporated into the Contract as specified in Section 104.02 of the Standard Construction Specifications.

No other terms or conditions of the Request for Competitive Price Quote are changed as a result of this addendum.