

# Clarification Log

**Project Number: P21101**

**Project Title: Downtown Lighting – Phase 1**

Date	Question	Response
07/23/14	What is the estimated project range?	The estimated project cost range for this project is between \$120,000.00 and \$150,000.00. This information is posted on the project website at <a href="http://www.springfield-or.gov/dpw/InvitationBid.htm">http://www.springfield-or.gov/dpw/InvitationBid.htm</a> .
07/23/14		A reminder to all bidders. All questions should be addressed to Terri White at <a href="mailto:twhite@springfield-or.gov">twhite@springfield-or.gov</a> . Contact with any other City officials may be grounds for disqualification of your bid.
07/28/14	<p>Specification Section B 1.5 (Bid Items/Bid Item No. 0248 and 0248b) states:  <i>Install Decorative Street Light (LED) - Scope: This bid item shall include all materials and labor to install, test, and place in service City Supplied decorative street light units. <b>The City shall provide: (1) Aluminum, 'Wadsworth', 'SiteLink' pole, and a Holophane, 'Washington' luminaire, and LED retrofit kit.</b></i></p> <p>Please confirm that the City is providing all 31 poles and luminaires required for this project.</p>	Yes, the City will provide all poles and fixtures required for the scope of work.
07/30/14	<p>Item No. 0248 &amp; 0248b contain approximate quantities of 26 &amp; 5. These quantities do not match the plan sheets or the light pole table on sheet SL5-6.</p> <p>Please confirm that for proposal purposes the contractor shall bid the approximate quantities rather than the quantities indicated on the light pole table.</p>	<p>The actual quantities shown on the Bid Submittal document are incorrect. The correct quantities are:</p> <p>Bid Item 0248 Install Decorative Street Light (LED)= 23 Each            Bid Item 0248b Install Decorative Street Light in Existing Foundation = 6 Each</p> <p>We will be issuing an addendum to address this correction.</p>
08/05/14	Is the City providing the anchor bolts? These are typically provided with the light poles and we cannot find it specifically mentioned in the specs. If so, it would make sense to tie the completion to receipt of the anchor bolts to minimize the time the construction zone is active.	Anchor bolts for new foundations are provided by City of Springfield and are included in the Holophane pole order and will be the first item to arrive. Hilti anchors for existing foundations are not provided by City of Springfield.

